



OHIO TURNPIKE AND INFRASTRUCTURE COMMISSION

ADDENDUM NO. 1

**BID INVITATION NO. 4281
FURNISHING A TWELVE MONTH SERVICE CONTRACT FOR THE INSPECTION, TESTING
AND REPAIR OF FIRE ALARM SYSTEMS, FIRE SPRINKLER SYSTEMS AND FIRE
SUPPRESSION/EXTINGUISHING SYSTEMS LOCATED IN VARIOUS COMMISSION
BUILDINGS**

EXTENDED OPENING DATE:
2:00 P.M. (EASTERN TIME), OCTOBER 21 31, 2016


ATTENTION OF BIDDERS IS DIRECTED TO:


EXTENSION ON THE BID OPENING DEADLINE

-AND-

ANSWERS TO QUESTIONS RECEIVED THROUGH 12:00PM ON OCTOBER 19, 2016

Issued by the Ohio Turnpike and Infrastructure Commission on October 19, 2016. Issuance authorized by Anthony D. Yacobucci, Chief Engineer, and Mark R. Musson, Director of Contract Administration.


Anthony D. Yacobucci 10-19-16
Date

 10/19/16
Mark R. Musson Date

ANSWERS TO QUESTIONS RECEIVED THROUGH END OF INQUIRY PERIOD:

Q#1 Wanted to see if anyone can provide the fire alarm field devices and FM-200 field devices per site location. Looking for the counts for all smoke detectors, pull station, duct detectors, monitor modules and relay modules.

A#1 Please see the number of FM-200 devices per location specified on Schedule A found at page 6b of the Invitation to Bid. The counts for the requested devices are provided in this Addendum No. 1 in the attached Exhibit A.

*Through this Addendum No. 1, the deadline for receiving bids is extended to the revised opening deadline of **2:00 PM on October 31, 2016.***

**Receipt of Addendum No. 1
Invitation No. 4281 is hereby acknowledged:**

(Firm Name) _____

(Signature) _____

(Printed Name) _____

(Date) _____

**BIDDERS MUST RETURN THE ABOVE ACKNOWLEDGEMENT
OF RECEIPT OF ADDENDUM NO. 1 WITH THEIR BID.**

OHIO TURNPIKE

Total Facility Devices/Equipment per 2016 Fire Alarm Inspection Report Summaries

Facility	Common Equipment				Initiating Devices						Notification Devices			Auxiliary		Total
	Control Panel	Power Supply	Annunc.	Battery	Pull Station	Smoke Detector	Heat Detector	Water Flow Switch	Tamper Switch	Duct Smoke Detector	Horn/Strobe	Indicating Light	Strobe	Door Hold	Duct Det. Test Switch	
Kunkle Maintenance	1			2	6	1		1			8					19
Swanton Maintenance	1		1	2	8			1	3		8					24
Elmore Maintenance	1			2	10	7	3			6	17					46
Castalia maintenance	1		1	2	8	2		1	2	1	9		1			28
Amherst Maintenance	1			2	8			1		2	10					24
Boston Maintenance	1			2	6	1		1	3	3	8					25
Hiram Maintenance	1		1	2	14	1	1	2	2	6	18		1			49
Canfield Maintenance	1		1	2	6	1		1	1	1	8					22
Indian Meadow Service Plaza	1	3	2	7	18	25	1	3	10	9	44	9	24			156
Tiffin River Service Plaza	1	3	1	7	18	26	1	3	10	9	43	9	26			157
Blue Heron Service Plaza	1	1	1	4	10	13	2			8	25		13	2	8	88
Wyandot Service Plaza	1	1	1	4	10	12	2			8	25		13	2	8	87
Erie Islands Service Plaza	1	2	1	6	8	10	8	1	10	10	23		12	2		94
Commodore Perry S. P.	1	1	1	4	8	10	8	1	8	10	24		14	2		92
Middle Ridge Service Plaza	2	1	1	6	14	14	4	1	4	8	37		13	4	8	117
Middle Ridge Pump House					2		2	1	4		1					10
Vermilion Valley Service Plaza	1	1	1	4	13	14	4			8	36		12	4	2	100
Great Lakes Service Plaza	1	0	0	4	8	5	2			8	20		16	2		66
Towpath Service Plaza	1	0	0	4	8	5	2	1	11	8	20		17	2		79
Portage Service Plaza	1	0	0	2	8	9	2	1	2	8	23		19	2		77
Brady's Leap Service Plaza	1	0	0	2	10	10	3	2	10	8	24		18	2		90
Mahoning Valley Service Plaza	1	1	2	4	14	13	1	3	12	10	53	9	16		1	140
Glacier Hills Service Plaza	1	1	2	4	14	13	1	3	12	10	51	9	17		1	139
Administration Building	1	1	1	4	14	8				4	24		15	1	2	75
Communications Building	1	0	1	2	10	4	5			4	12		7		4	50

1,854