

OHIO TURNPIKE AND INFRASTRUCTURE COMMISSION

ADDENDUM NO. 2

**BID INVITATION NO. 4262
FURNISHING HIGH BAY LED LIGHTING**

OPENING DATE:

2:00 P.M. (EASTERN TIME), JANUARY 27, 2016

ATTENTION OF BIDDERS IS DIRECTED TO:

**ANSWERS TO QUESTIONS RECEIVED
THROUGH 5:00PM ON JANUARY 22, 2016**

ANSWERS TO QUESTIONS RECEIVED THROUGH 5:00 P.M., JANUARY 22, 2016:

Q#9 I wanted to get back with you to the answer to my question. I would like to submit the Energy Focus 18W Clear tubular LED LEDFLT8-850-418-3B2C/F as an equal. Attached is the SPEC sheet for this product. Item number 1: I would use a 6 lamp fixture with 6 of the 18W LEDFLT8-850-418-3B2C/F (total 108W) and 14,040 Lumens with an L70 rating of 50,000 hours which is also the warranty. Item number 2: I would use a 8 lamp fixture with 8 of the 18W LEDFLT8-850-418-3B2C/F (total 144W) and 18,720 Lumens with an L70 rating of 50,000 hours which is also the warranty.

A#9 The proposed equals are rejected because there is not enough information regarding the fixtures and the LED Lumen Rating does not meet the L70 minimum specified.

Q#10 I would like to submit two fixtures for consideration as a proposed equal. The manufacturer is FlexTronics in Kansas and the Fixture line is the Lusio® Essentials Series – Value. I have attached a summary sheet, all spec sheets, ies files, CAD drawings and T&C with warranty information for this product. Here is the manufacturer’s website for your review: http://www.lusiolighting.com/fixtures/essentials_value_overview.asp

A#10 The proposed equals are rejected because they do not conform to the specifications for being lens-less.

**Receipt of Addendum No. 2
Invitation No. 4262 is hereby acknowledged:**

(Firm Name) _____

(Signature) _____

(Printed Name) _____

(Date) _____

**BIDDERS MUST RETURN THE ABOVE ACKNOWLEDGEMENT
OF RECEIPT OF ADDENDUM NO. 1 WITH THEIR BID.**