

ANSWERS TO QUESTIONS RECEIVED THROUGH 11:00 AM ON JANUARY 23, 2019:

Q#1 What is the generation process of the slag waste water? (is this storm water, if so, why reason is it not allowed to be discharged to a creek?)

A#1 This slag leachate wastewater is storm water that comes into contact with the slag backfill used in the reconstruction of the interchange in 1999, which generates a sulfur leachate. This sulfur leachate has been deemed by the EPA as unfit to release into surrounding waterways, therefore it is required to be collected and properly treated to avoid additional impact to the surrounding environment.

Q#2 The bid says price must include sampling and analytics. Does the turnpike require us to turn in and/or do sampling, or is that line there to signal that we are responsible for whatever testing we want to do?

A#2 The Contractor is responsible for any and all sampling and analytics required by their disposal facility and/or EPA regulations on hauling and disposal. The Testing Information provided in the attachments of this Bid Invitation is performed by a separate vendor and not required as part of this Bid Invitation.

Q#3 Regarding invitation # 4334, Leachate water removal, transportation ,and disposal, can you confirm the current vendor and costs for this work?

A#3 The previous bid tab is available here: <https://www.ohioturnpike.org/docs/default-source/Procurement/results923c89f6cc96651db1daff000092862f.pdf?sfvrsn=0>

Note, however, the previous bid contained two options for the Commission to renew the contract. The current bid requests pricing for one year with no renewal options.

Addendum No. 1

Invitation No. 4334 is hereby acknowledged:

(Firm Name) _____

(Signature) _____

(Printed Name) _____

(Date) _____

THE FOREGOING RESPONSES ARE INCORPORATED INTO THE INVITATION TO BID