OTIC Project No. 58-20-01
Ohio Turnpike: Toll Plaza Construction
Milepost 49, Lucas County, Ohio

SUBSTITUTION REQUEST

(Use separate form for each request)

Date: May 11, 2020 Request No.: 1

TO: Kevin.Colick@ohioturnpike.org / Victoria.Kullik@Ohioturnpike.org

Phone: _____

PROJECT: Toll Plaza Construction Milepost 49 Project No.: 58-20-01

TRADE CONTRACTOR: Control System of Ohio

SPECIFIED ITEM: Direct Digital Control System

Section: 230923 Page: 248 Paragraph: 2.1 Description: DDC System Manufacturers

Drawing Number(s): M114 Detail Number(s): _____

The undersigned request consideration of the following:

PROPOSED SUBSTITUTION: Automated Logic WebCTRL, GSCE, SE controllers ZN controllers, RS Pro,

REASON FOR NOT GIVING PRIORITY TO SPECIFIED ITEMS: _____

SAVINGS or CREDIT to OWNER for ACCEPTING SUBSTITUTE: $ equal

Attached data includes description, Specifications, Drawings, photographs, performance and test data adequate for evaluation of the request; applicable portions of the data are clearly identified.

Attached data also includes a description of changes to the Contract Documents that the proposed substitution will require for its proper installation.

OTIC Project No. 58-20-01
Ohio Turnpike: Toll Plaza Construction
Milepost 49, Lucas County, Ohio

The undersigned certifies that the following paragraphs, unless modified by attachments, are correct:

1. Proposed substitution has been fully checked and coordinated with the Contract Documents.
2. The proposed substitution does not affect dimensions shown on Drawings.
3. The proposed substitution does not require revisions to mechanical or electrical work.
4. The undersigned will pay for changes to the building design, including architectural and engineering design, detailing, and construction costs caused by the requested substitution.
5. The proposed substitution will have no adverse effect on other trades, the construction schedule, or specified warranty requirements.
6. Maintenance and service parts will be locally available for the proposed substitution.

The undersigned further states that the function, appearance, and quality of the proposed substitution are equivalent or superior to the specified item.

Attachments: The attached data is furnished herewith for evaluation of the proposed substitution.

☐ Catalog ☐ Drawings ☐ Samples ☐ Reports ☐ Tests ☐ Other: _____

Submitted by:

Control Systems of Ohio (CSO) _____
(Firm) (Authorized Legal Signature)

4953 Harroun Road, Sylvania, Ohio (419) 309-2443
(Address) (Telephone)

For use by the Architect: ☐ Accepted ☐ Accepted as Noted ☒ Rejected: Submit Specified Item

BY: Mike Murphy, Architect
(Authorized Signature)

Date: 05/13/2020 Remarks: Honeywell is the preferred control system by OTIC